

IFUX

June 14, 1996

Fixtures For Use In Hazardous Locations

**JERGUSON GAGE & VALVE CO, SUB OF CLARK
RELIANCE CORP , STRONGSVILLE OH 44138**

E22696 (N)

Class I, Groups A, B, C and D;

Class I, Groups C and D; Class I, Group B, Division 2.

Lighting fixtures, threaded for rigid conduit connection.

Class I, Groups C and D; Class I, Group B, Division 2.

Cat. Nos. EPL-54, -56, rated 50 W max. at 250 V max. and 58 W max. at 120 V max., 50/60 Hz.

Insulation for supply conductors should be suitable for 75 C.

Class I, Groups A, B, C and D.

Cat. No. EPL-60 followed by 1 to 9 incl., followed by 0, 1 or 2, followed by 1, 2 or 3, rated 4.85 W max., 230 V max., 50/60 HZ. Insulation of supply conductors should be suitable for 75 C.

16833 FOLTZ PKWY

LOOK FOR LISTING MARK ON PRODUCT

Replaces E22696 dated February 22, 1993.

368897001

Underwriters Laboratories Inc.®

G11/0056003